



Village of Sussex Fire Department
N64 W23760 Main Street
Sussex, Wisconsin 53089-0249

Fire Chief *Colin P. Curtis*
262-246-5197
Inspector *Greg Zoellick*
262-246-5220
Fire Station - *Business*
262-246-5197
Fire Station - *FAX*
262-246-5196

Village of Sussex Fire Department requirements of Mobile food Vendor

Inspections are not required if the following conditions are met:

Mobile truck/trailer is less than 365 sq/ft

Mobile truck/trailer is used less than 12 days a year.

Requirements include but not limited to:

A UL listed fire extinguisher equal to or greater than 2A 10BC that has been recertified within the last twelve months.

Any deep frying, pan frying or cooking meats on a grill or griddle also require a K Class fire extinguisher fire extinguisher that has been re-certified within the last twelve months.

Generators, gasoline cans and solid fuel tanks must be kept outside of truck/trailer.

Compressed gas cylinders must be secured from falling.

An inspection is required if:

Mobile truck/trailer is greater than 365 sq/ft.

Mobile/trailer is used more than 12 days a year.

Requirements include but not limited to:

A UL listed fire extinguisher equal to or greater than 2A 10BC that has been recertified within the last twelve months.

Any deep frying, pan frying or cooking meats on a grill or griddle also require a hood exhaust system with a suppression system that has been re-certified and cleaned within the required time.

K Class fire extinguisher that has been re-certified within the last twelve months.

Generators, gasoline cans and solid fuel tanks must be kept outside of truck/trailer.

Compressed gas cylinders must be secured from falling.



Proudly Serving the Community Since 1922

